



Date: 10-OCT-19  
 PO No.: 1517879  
 WO No.: L2359361  
 LSD:

Project Ref: NOOTKA ELEMENTARY  
 Sample ID: CORR 131 RM 130 DF  
 Sampled By: ROBIN LENAY  
 Date Collected: 03-OCT-19  
 Lab Sample ID: L2359361-3  
 Matrix: WATER

VANCOUVER SCHOOL BOARD  
 Maintenance and Construction  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b>						
Lead (Pb)-Total	0.000466		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.</p> <p>* Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality</p> <p>- A blank entry designates no known limit.</p> <p>- A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						

Approved by   
 Edward Ngai  
 Account Manager



Date: 10-OCT-19  
 PO No.: 1517879  
 WO No.: L2359361

LSD:  
 Project Ref: NOOTKA ELEMENTARY  
 Sample ID: CORR 100 RM 103 DF  
 Sampled By: ROBIN LENAY  
 Date Collected: 03-OCT-19  
 Lab Sample ID: L2359361-5  
 Matrix: WATER

VANCOUVER SCHOOL BOARD  
 Maintenance and Construction  
 1549 Clark Drive  
 Vancouver BC V5L 3L4  
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b>						
Lead (Pb)-Total	0.00185		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						

Approved by   
 Edward Ngai  
 Account Manager



**VANCOUVER SCHOOL BOARD**  
**Maintenance and Construction**  
**1549 Clark Drive**  
**Vancouver BC V5L 3L4**  
**ATTN: Stephen Thomas**

**Date:** 10-OCT-19  
**PO No.:** 1517879  
**WO No.:** L2359361  
**LSD:**  
**Project Ref:** NOOTKA ELEMENTARY  
**Sample ID:** CORR 183 RM 167 SSDF  
**Sampled By:** ROBIN LENAY  
**Date Collected:** 03-OCT-19  
**Lab Sample ID:** L2359361-6  
**Matrix:** WATER

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b>						
Lead (Pb)-Total	0.000081		mg/L	0.005		08-OCT-19
<b>CDWQG = Health Canada Guideline Limits updated</b>		<b>JUNE 2019</b>				
<p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L &lt; or N.D. = less than detection limit.            * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality            - A blank entry designates no known limit.            - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						

Approved by   
 Edward Ngai  
 Account Manager



Date: 10-OCT-19  
PO No.: 1517879  
WO No.: L2359361

LSD:  
Project Ref: NOOTKA ELEMENTARY  
Sample ID: CORR 131 RM 106 SSDF  
Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19  
Lab Sample ID: L2359361-4  
Matrix: WATER

VANCOUVER SCHOOL BOARD  
Maintenance and Construction  
1549 Clark Drive  
Vancouver BC V5L 3L4  
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
<b>Total Metals</b>						
Lead (Pb)-Total	0.000594		mg/L	0.005		08-OCT-19
<b>CDWQG = Health Canada Guideline Limits updated JUNE 2019</b>						
* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit.						
* Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality						
- A blank entry designates no known limit.						
- A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.						

Approved by   
Edward Ngai  
Account Manager