



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 131 FS

Sampled By: ROBIN LENAY


Date Collected: 03-OCT-19

Lab Sample ID: L2359358-1

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

PAGE 1 of 16

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000502		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 139 RM106 DF


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-2

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00190		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 146 RM114C DF


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-3

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000568		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 116 BUB


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-4

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000743		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM118 BUB


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-5

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00102		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 240 RM 217 DF

Sampled By: ROBIN LENAY


Date Collected: 03-OCT-19

Lab Sample ID: L2359358-6

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

PAGE 6 of 16

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000618		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700

ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 240 RM 207 DF


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-7

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000393		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 250 DF


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-8

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000482		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 224 FS


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-9

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000406		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 327 RM 328 SSDF


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-10

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
 1549 Clark Drive
 Vancouver BC V5L 3L4
 ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000815		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 332 RM 317 D


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-11

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000322		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 302 FS


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-12

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000720		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: CORR 201 RM 202 DF


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-13

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000991		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 236 BUB


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-14

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.000752		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						



Date: 10-OCT-19

PO No.: 1517879

WO No.: L2359358

LSD:

Project Ref: WINDERMERE SECONDARY

Sample ID: RM 237 BUB


Sampled By: ROBIN LENAY

Date Collected: 03-OCT-19

Lab Sample ID: L2359358-15

Matrix: WATER

VANCOUVER SCHOOL BOARD
Maintenance and Construction
1549 Clark Drive
Vancouver BC V5L 3L4
ATTN: Stephen Thomas

Test Description	Result	Qualifier	Units of Measure	CDWQG MAC	Aesthetic Objective	Date Analyzed
Total Metals Lead (Pb)-Total	0.00182		mg/L	0.005		08-OCT-19
<p>CDWQG = Health Canada Guideline Limits updated JUNE 2019</p> <p>* CDWQG for Nitrate+Nitrite-N is the limit for nitrate only. If present as Nitrate then the limit is 10mg/L < or N.D. = less than detection limit. * Turbidity guideline based on membrane filtration. For guidelines on conventional treatment and slow sand or diatomaceous earth filtration please see Summary Table of Guidelines for Canadian Drinking Water Quality - A blank entry designates no known limit. - A shaded value in the Results column exceeds CDWQG MAC and/ or Aesthetic Objective.</p>						
<p>Approved by  Edward Ngai Account Manager</p>						

Guidelines & Objectives

Health Canada MAC Health Related Criteria Limits

Nitrate/Nitrite-N*	Criteria limit is 10 mg/L (1.0 mg/L if present as all Nitrite-N). High concentrations may contribute to blue baby syndrome in infants.
Lead*	A cumulative body poison, uncommon in naturally occurring hard waters.
Fluoride*	Present in fluoridated water supplies at 0.8 mg/L to reduce dental caries. Elevated levels causes fluorosis (mottling of teeth).
Total Coliforms*	Criteria is 0 CFU/100mL. Adverse health effects.
E. Coli*	Criteria is 0 CFU/100 mL. Certain E. Coli bacteria can be life threatening.
Manganese*	Criteria limit is 0.12 mg/L. Possible neurological effects in infants.

*Health Canada Canadian Drinking Water Quality Guidelines (MAC limit)

Aesthetic Objective Concentration Levels

Alkalinity	Acid neutralizing capacity. Usually a measure of carbonate and bicarbonates and calculated and reported as calcium carbonate.
Balance	Quality control parameter ratiating cations to anions
Bicarbonate	See Alkalinity. Report as the anion HCO ₃ -1
Carbonate	See Alkalinity. Reported at the anion CO ₃ -2
Calcium	See Hardness. Common major cation of water chemistry.
Chloride	Common major anion of water chemistry.
Conductance	Physical test measuring water salinity (dissolved ions or solids)
Hardness	Classical measure or capacity of water to precipitate soap (chiefly calcium and magnesium ions). Causes scaling tendency in water if carbonates/bicarbonates are present (if >200 mg/L). For drinking water purposes waters with results <200 mg/L are considered acceptable, results >200 mg/L are considered poor but can be tolerated. Results >500 mg/L are unacceptable.
Hydroxide	See alkalinity
Magnesium	See hardness. Common major cation of water chemistry. Elevated levels (>125 mg/L) may exert a cathartic or diuretic action.
pH	Measure of water acidity/alkalinity. Normal range is 7.0-8.5.
Potassium	Common major cation of water chemistry.
Sodium	Common major cation of water chemistry. Measure of salinity (saltiness).
Sulphate	Common major anion of water chemistry. Elevated levels may exert a cathartic or diuretic action.
Total Dissolved Solids	A measure of water salinity.
Iron	Causes staining to laundry and porcelain and astringent taste. Oxidizes to red-brown precipitate on exposure to air.
Heterotrophic	
Plate Count	Criteria is 500 cfu/mL Measure of heterotrophic bacteria present.

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.



Chain of Custody (COC) / Analytical Request Form

Canada Toll Free: 1 800 668 9878

www.alsglobal.com



COC Number: 17 - 756182

Page 1 of 2

Report To Contact and company name below will appear on the final report		Report Format / Dis Select Report Format: <input checked="" type="checkbox"/> PDF <input type="checkbox"/> EXCEL <input type="checkbox"/> WORD (DIGITAL)		Contact your AM to confirm all E&P TATs (surcharges may apply)							
Company: <u>Vancouver School Board</u>		Quality Control (QC) Report with Report <input type="checkbox"/> YES <input type="checkbox"/> NO		Regular (R) <input checked="" type="checkbox"/> Standard TAT if received by 3 pm - business days - no surcharges apply		EMERGENCY					
Contact: <u>Stephen Thomas</u>		<input type="checkbox"/> Compare Results to Criteria on Report - provide details below if box checked		4 day [P4-20%] <input type="checkbox"/>		1 Business day [E - 100%] <input type="checkbox"/>					
Phone: <u>604-713-5637</u>		Select Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX		3 day [P3-25%] <input type="checkbox"/>		Same Day, Weekend or Statutory holiday (E2 -200% [Laboratory opening fees may apply]) <input type="checkbox"/>					
Company address below will appear on the final report		Email 1 or Fax: <u>ssthenas@vsb.bc.ca</u>		Date and Time Required for all E&P TATs:		dd-mmm-yy hh:mm					
Street: <u>1549 Clark Dr.</u>		Email 2: <u>rlemay@vsb.bc.ca</u>		For tests that can not be performed according to the service level selected, you will be contacted.							
City/Province: <u>Vancouver B.C.</u>		Email 3:		Analysis Request							
Postal Code:				Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below							
Invoice To		Invoice Distribution		NUMBER OF CONTAINERS	Lead	SAMPLES ON HOLD	SUSPECTED HAZARD (see Special Instructions)				
Same as Report To <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		Select Invoice Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX									
Copy of Invoice with Report <input type="checkbox"/> YES <input type="checkbox"/> NO		Email 1 or Fax: <u>ssthenas@vsb.bc.ca</u>									
Company:		Email 2: <u>rlemay@vsb.bc.ca</u>									
Contact:		Oil and Gas Required Fields (client use)									
Project Information		AFECost Center: PO#									
ALS Account # / Quote #:		Major/Minor Code: Routing Code:									
Job #: <u>Windsmere Secondary</u>		Requisitioner:									
PO / AFE:		Location:									
LSD:		ALS Contact:									
ALS Lab Work Order # (lab use only):		Sampler: <u>Robin Lemay</u>									
ALS Sample # (lab use only)	Sample Identification and/or Coordinates (This description will appear on the report)	Date (dd-mmm-yy)	Time (hh:mm)	Sample Type							
	<u>Rm. 131 FS</u>	<u>03-10-19</u>	<u>7:03am</u>	<u>water</u>							
	<u>Corr 139 Rm. 106 DF</u>	<u>03-10-19</u>	<u>7:09am</u>	<u>water</u>							
	<u>Corr 146 Rm. 114c DF</u>	<u>03-10-19</u>	<u>7:15am</u>	<u>water</u>							
	<u>Rm. 116 Bub</u>	<u>03-10-19</u>	<u>7:21am</u>	<u>water</u>							
	<u>Rm. 118 Bub</u>	<u>03-10-19</u>	<u>7:26am</u>	<u>water</u>							
	<u>Corr 240 Rm. 217 DF</u>	<u>03-10-19</u>	<u>7:37am</u>	<u>water</u>							
	<u>Corr 240 Rm. 207 DF</u>	<u>03-10-19</u>	<u>7:42am</u>	<u>water</u>							
	<u>Rm. 250 DF</u>	<u>03-10-19</u>	<u>7:49am</u>	<u>water</u>							
	<u>Rm. 224 FS</u>	<u>03-10-19</u>	<u>7:59am</u>	<u>water</u>							
	<u>Corr 327 Rm. 328 SSDF</u>	<u>03-10-19</u>	<u>8:07am</u>	<u>water</u>							
	<u>Corr 332 Rm. 317 D</u>	<u>03-10-19</u>	<u>8:12am</u>	<u>water</u>							
	<u>Rm. 302 FS</u>	<u>03-10-19</u>	<u>8:18am</u>	<u>water</u>							
Drinking Water (DW) Samples¹ (client use)		Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below (electronic COC only)		SAMPLE CONDITION AS RECEIVED (lab use only)							
Are samples taken from a Regulated DW System? <input type="checkbox"/> YES <input type="checkbox"/> NO		<u>No preservatives added</u>		Frozen <input type="checkbox"/> SIF Observations Yes <input type="checkbox"/> No <input type="checkbox"/>							
Are samples for human consumption/ use? <input type="checkbox"/> YES <input type="checkbox"/> NO				Ice Packs <input checked="" type="checkbox"/> Ice Cubes <input type="checkbox"/> Custody seal intact Yes <input type="checkbox"/> No <input type="checkbox"/>							
				Cooling initiated <input type="checkbox"/>							
				INITIAL COOLER TEMPERATURES °C		FINAL COOLER TEMPERATURES °C					
						<u>9.12°C</u>					
SHIPMENT RELEASE (client use)		INITIAL SHIPMENT RECEPTION (lab use only)		FINAL SHIPMENT RECEPTION (lab use only)							
Released by:	Date:	Time:	Received by:	Date:	Time:	Received by: <u>JG</u>	Date: <u>3 Oct 19</u>				
							Time: <u>12:20 PM</u>				

REFER TO BACK PAGE FOR ALS LOCATIONS AND SAMPLING INFORMATION

WHITE - LABORATORY COPY YELLOW - CLIENT COPY

1. If any water samples are taken from a Regulated Drinking Water (DW) System, please submit using an Authorized DW COC form.

L2359358-COFC

Report To <small>Contact and company name below will appear on the final report</small>		Report Format / Distribution		Standard TAT <small>Standard TAT if received by 3 pm - business days - no surcharges apply</small>	
Company: Vancouver School Board	Select Report Format: <input checked="" type="checkbox"/> PDF <input type="checkbox"/> EXCEL <input type="checkbox"/> EDD (DIGITAL)	Regular [R] <input checked="" type="checkbox"/>	Standard TAT if received by 3 pm - business days - no surcharges apply		
Contact: Stephen Thomas	Quality Control (QC) Report with Report <input type="checkbox"/> YES <input type="checkbox"/> NO	4 day [P4-20%] <input type="checkbox"/>	3 day [P3-25%] <input type="checkbox"/>	2 day [P2-50%] <input type="checkbox"/>	1 Business day [E - 100%] <input type="checkbox"/>
Phone: 604-713-5637	<input type="checkbox"/> Compare Results to Criteria on Report - provide details below if box checked	Emergency			
<small>Company address below will appear on the final report</small>		Select Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX		Same Day, Weekend or Statutory holiday [E2 -200%] <input type="checkbox"/> <small>(Laboratory opening fees may apply)</small>	
Street: 1549 Clark Dr.	Email 1 or Fax: ssthenas@vsb.bc.ca	Date and Time Required for all E&P TATs:			dd-mmm-yy hh:mm
City/Province: Vancouver BC	Email 2: rlemay@vsb.bc.ca	<small>For tests that can not be performed according to the service level selected, you will be contacted.</small>			
Postal Code:	Email 3:	Analysis Request			

Invoice To		Invoice Distribution	
Same as Report To <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	Copy of Invoice with Report <input type="checkbox"/> YES <input type="checkbox"/> NO	Select Invoice Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX	
Project Information		Oil and Gas Required Fields (client use)	
ALS Account # / Quote #:	AFE/Cost Center:	PO#	
Job #: Windermere Secondary	Major/Minor Code:	Routing Code:	
PD / AFE:	Requisitioner:		
LSD:	Location:		
ALS Lab Work Order # (lab use only):	ALS Contact:	Sampler: Robin Leman	

ALS Sample # (lab use only)	Sample Identification and/or Coordinates <small>(This description will appear on the report)</small>	Date <small>(dd-mmm-yy)</small>	Time <small>(hh:mm)</small>	Sample Type	NUMBER OF CONTAINERS	Indicate Filtered (F), Preserved (P) or Filtered and Preserved (FIP) below										SAMPLES ON HOLD	SUSPECTED HAZARD (see Special Instructions)
	Corr 201 Rm 202 DF	03-10-19	8:29am	water	Lead												
	Rm. 236 Bub	03-10-19	8:35am	water													
	Rm. 237 Bub	03-10-19	8:40am	water													

Drinking Water (DW) Samples¹ (client use)		Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below <small>(electronic COC only)</small>		SAMPLE CONDITION AS RECEIVED (lab use only)	
Are samples taken from a Regulated DW System? <input type="checkbox"/> YES <input type="checkbox"/> NO	Are samples for human consumption/ use? <input type="checkbox"/> YES <input type="checkbox"/> NO	No preservatives added		Frozen <input type="checkbox"/>	SIF Observations Yes <input type="checkbox"/> No <input type="checkbox"/>
				Ice Packs <input type="checkbox"/> Ice Cubes <input type="checkbox"/>	Custody seal intact Yes <input type="checkbox"/> No <input type="checkbox"/>
				Cooling Initiated <input type="checkbox"/>	
SHIPMENT RELEASE (client use)		INITIAL SHIPMENT RECEPTION (lab use only)		FINAL SHIPMENT RECEPTION (lab use only)	
Released by:	Date:	Time:	Received by:	Date:	Time: